



FOR USE ONLY WHERE INDICATED ON PLANS  
 THE CONCRETE ENCASEMENT SHALL BE OF 3000 PSI CONCRETE  
 WITH A MINIMUM THICKNESS ON ALL SIDES OF 6".

1. 8" DIA. = .11 C.Y. OF CONCRETE PER LINEAL FT.
2. 10" DIA. = .12 C.Y. OF CONCRETE PER LINEAL FT.
3. 12" DIA. = .14 C.Y. OF CONCRETE PER LINEAL FT.
4. 15" DIA. = .15 C.Y. OF CONCRETE PER LINEAL FT.

GARDNER, KANSAS <u>PUBLIC</u> <u>WORKS/</u> <u>ENGINEERING</u> <u>DIVISION</u>	APPROVED	REVISED	CONCRETE ENCASEMENT DETAIL	STANDARD DETAIL 30-1
	<u>JRH</u> CITY ENGINEER	_____		
	<u>2-1-07</u> DATE	_____		
	_____	_____		