



NOTES:

1. ALIGNMENT OF PVC WATER LINE AROUND CUL-DE-SAC VARIES TO MAINTAIN CLEARANCE FROM SAN. SEWER.
2. MAIN TO BE EXTENDED TO INSURE D.I.P. WATER LINE IS LOCATED ON PROPERTY LINE FOR FUTURE TAPPING PURPOSES.
3. FOR FIRE HYDRANT ASSEMBLY DETAILS SEE STD. DETAIL 50-2
4. FOR FLUSHING ASSEMBLY DETAILS SEE STD. DETAIL 50-3.
5. VALVES TO BE LOCATED OUTSIDE OF SIDEWALK.

<b>GARDNER, KANSAS PUBLIC WORKS/ ENGINEERING DIVISION</b>	APPROVED	REVISED	<b>END OF LINE ON CUL-DE-SAC</b>	STANDARD DETAIL  50-8
	<u>JRH</u> CITY ENGINEER	_____		
	2-1-07 DATE	_____		
	_____	_____		