



* IN FILL SITUATIONS, 12" BELOW EXISTING GRADE
 ** IF COVER OVER PIPE IS LESS THAN 2 FT., USE CA-5 TO 6" ABOVE TOP OF PIPE,
 THEN REMOVABLE FLOWABLE FILL TO BOTTOM OF ASPHALT PAVEMENT.
 THIS DETAIL IS APPLICABLE FOR TRENCHING OF ALL CONDUITS UNDER FUTURE STREETS,
 INCLUDING WATER, SANITARY SEWER, AND STORM SEWERS, ETC..

GARDNER, KANSAS <u>PUBLIC</u> <u>WORKS/</u> <u>ENGINEERING</u> <u>DIVISION</u>	APPROVED	REVISED	TRENCHING UNDER FUTURE STREET	STANDARD DETAIL 60-3
	JRH CITY ENGINEER	_____		
	2-1-07	_____		
	DATE	_____		